

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Certificate

Certificate Reference Number :

MMD005

Details of Client :

MUSIK MACHINE MOBILE DISCO

Test Equipment Details :

Test Equipment used : SEAWARD APOLLO 600
Tested by : Steve Wilson

Serial Number : 42F-0621
Date: 06/09/2025
Re-test date : 06/09/2026

Serial number	Make and Model	Location	Voltage (V)	Rating (A)	Fuse Rating (A)	Insulation Resistance	Earth Continuity	Plug, Flex and Body OK	OK to use ?
955	EQUINOX GOBO	N/A	230	N/A	N/A	>20MΩ	P	P	Y
956	EQUINOX CROSSFIRE XP	N/A	230	N/A	N/A	>20MΩ	P	P	Y
957	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
958	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
959	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
960	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
961	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
962	DENNON PSU	N/A	230	13A	13A	>20MΩ	P	P	Y
963	REMOTE SOCKET	N/A	230	13A	13A	>20MΩ	P	P	Y
964	EQUINOX UV FLOOD	N/A	230	13A	13A	>20MΩ	P	P	Y
965	ROTOSPHERE Q3	N/A	230	N/A	N/A	>20MΩ	P	P	Y
966	DENON DJ MC 6000	N/A	N/A	N/A	N/A	>20MΩ	P	P	Y
967	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
968	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
969	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
970	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
971	MEGA TRIPAR PLUS	N/A	230	N/A	N/A	>20MΩ	P	P	Y
972	MEGA TRIPAR PLUS	N/A	230	N/A	N/A	>20MΩ	P	P	Y
973	MEGA TRIPAR PLUS	N/A	230	N/A	N/A	>20MΩ	P	P	Y
974	MEGA TRIPAR PLUS	N/A	230	N/A	N/A	>20MΩ	P	P	Y
975	CHAUVET SWARM WASH FX	N/A	230	13A	13A	>20MΩ	P	P	Y
976	STAR CLOTH CONTROLLER	N/A	230	13A	13A	>20MΩ	P	P	Y
977	EQUINOX CONTROLLER	N/A	230	13A	13A	>20MΩ	P	P	Y
978	QUAD CLOTH CONTROLLER	N/A	230	13A	13A	>20MΩ	P	P	Y
979	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
980	ILS COMMAND PSU	N/A	230	13A	13A	>20MΩ	P	P	Y
981	CHAUVET ILS COMMAND	N/A	230	13A	13A	>20MΩ	P	P	Y
982	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
983	EVOX 8 SPEAKER	N/A	230	N/A	N/A	>20MΩ	P	P	Y
984	EVOX 8 SPEAKER	N/A	230	N/A	N/A	>20MΩ	P	P	Y
985	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
986	MICROPHONE PSU	N/A	230	5A	5A	>20MΩ	P	P	Y
987	REMOTE MICROPHONE UNIT	N/A	230	13A	13A	>20MΩ	P	P	Y
988	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
989	CHAUVET GIG BAR MOVE ILS	N/A	230	N/A	N/A	>20MΩ	P	P	Y
990	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
991	CHAUVET GIG BAR MOVE ILS	N/A	230	N/A	N/A	>20MΩ	P	P	Y
992	MICROPHONE PSU	N/A	230	5A	5A	>20MΩ	P	P	Y
993	REMOTE MICROPHONE UNIT	N/A	230	13A	13A	>20MΩ	P	P	Y
994	LED PARTY LIGHT	N/A	230	13A	13A	>20MΩ	P	P	Y
995	LED PARTY LIGHT	N/A	230	13A	13A	>20MΩ	P	P	Y
996	LED PARTY LIGHT	N/A	230	13A	13A	>20MΩ	P	P	Y
997	LED PARTY LIGHT	N/A	230	13A	13A	>20MΩ	P	P	Y
998	LED PARTY LIGHT	N/A	230	13A	13A	>20MΩ	P	P	Y
999	LED PARTY LIGHT	N/A	230	13A	13A	>20MΩ	P	P	Y
1000	DENNON PSU	N/A	230	13A	13A	>20MΩ	P	P	Y
1001	DENON DJ MC 6000	N/A	N/A	N/A	N/A	>20MΩ	P	P	Y
1002	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1003	4 GANG LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1004	4 GANG LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Certificate

Certificate Reference Number :

MMD005

Details of Client :

MUSIK MACHINE MOBILE DISCO

Test Equipment Details :

Test Equipment used : SEAWARD APOLLO 600
Tested by : Steve Wilson

Serial Number : 42F-0621
Date: 06/09/2025
Re-test date : 06/09/2026

Serial number	Make and Model	Location	Voltage (V)	Rating (A)	Fuse Rating (A)	Insulation Resistance	Earth Continuity	Plug, Flex and Body OK	OK to use ?
1005	4 GANG LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1006	4 GANG LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1007	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1008	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1009	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1010	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1011	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1012	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1013	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1014	6 GANG LEAD (SURGE)	N/A	230	13A	13A	>20MΩ	P	P	Y
1015	4 GANG LEAD (SURGE)	N/A	230	13A	13A	>20MΩ	P	P	Y
1016	REMOTE SOCKET	N/A	230	13A	13A	>20MΩ	P	P	Y
1017	REMOTE SOCKET	N/A	230	13A	13A	>20MΩ	P	P	Y
1018	REMOTE SOCKET	N/A	230	13A	13A	>20MΩ	P	P	Y
1019	REMOTE SOCKET	N/A	230	13A	13A	>20MΩ	P	P	Y
1020	HP LAPTOP PSU	N/A	230	5A	5A	>20MΩ	P	P	Y
1021	HP LAPTOP PSU	N/A	230	5A	5A	>20MΩ	P	P	Y
1022	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1023	IEC LEAD	N/A	230	13A	13A	>20MΩ	P	P	Y
1024	HP LAPTOP RED	N/A	230	13A	13A	>20MΩ	P	P	Y
1025	HP LAPTOP BLACK	N/A	230	13A	13A	>20MΩ	P	P	Y

Individual Certificates Are Available On Request

All tests carried out with : SEAWARD APPOLO 600 TESTER

Serial Number : 42F-0621

Calibrated : 16 FEBRUARY 2022

Certificate Number : PTS027084